

K.E.G. PLUMBING & MECHANICAL, INC.
 3148 ATLANTA HWY
 DALLAS, GA 30132
 PH: 770-445-2224



INVOICE NO
 14590

CUST Dekalb County Schools System
 1780 Montreal Road
 Tucker, GA 30084

SITE DCSD: Dresden Elementary
 2449 Dresden Dr
 Chamblee, GA 30341

ACCOUNT NO	INVOICE DATE	TERMS	DUE DATE			PAGE
DEKAL	12/30/2023	Net 30	1/29/2024			1

ORDER 8685, PO

DESCRIPTION Flow Test conducted previously
 Update from flow test, no flow found to hydrants, investigate and resolve, locator necessary, vault in front right

RESOLUTION Arrived onsite 12/4/23 and conducted initial flow test on 4 hydrants and all failed due to no flow, additional work is necessary to determine cause.

Arrived onsite 12/19/23 to address the fire hydrants. Determined the fire backflow was off on the city side, called watershed out and found the valve was off in the street. Checked the fire device, no sign of water being used, left it on. Will return.

Arrived onsite 12/20/23 checked flow to all hydrants. All four opened full and shut off. Checked the backflow, made sure that both shut off and holding. Cleaned area.

Returned and conducted officail flow test and all hydrants passed, job is complete.

Testing fees is based on 4 hydrants and failing on first flow test, then resolving the issue and retesting.

ITEM NO	QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED
DEKALB1TECH	3	Dekalb Labor 1 Technician	95.00	285.00*
DCSDHYDRANTT EST	8	DCSD Hydrant Flow Test	250.00	2,000.00*
DEKALB1TECH	2.5	Dekalb Labor 1 Technician	95.00	237.50*

A finance charge of 1.5% per month (18% annual percentage rate) will be charged on all invoices over 30 days old.

TOTAL AMOUNT 2,522.50

* means item is non-taxable